

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1429:125 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Secutron, Div. of Digital Security Controls LTD, 3301 Langstaff Rd, Concord, ON L4K 4L2
Contact: Paul Mattern (978) 731-8542 FAX (978) 731-8881

DESIGN: Models MR-D1010-R1 and MR-D1010-R2 Fiber Optic Modems used to interconnect specified fire alarm control and annunciator panels. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 V dc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL Label

APPROVAL: Listed as control unit accessories for use with separately listed Models MR-2900 (CSFM Listing No. 7165-1429:100 or 7170-1429:105), MR-2100 or MR-2200 (CSFM Listing No. 7165-1429:119 or 7170-1429:121) fire alarm control units and listee's Model MR-2944 (CSFM Listing No. 7120-1429:103) remote annunciator. Refer to listee's Installation Instruction Manual for details

12-17-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**